

REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
0	ISSUED FOR REVIEW		

CONCRETE TEST BOX WITH CAST
IRON LID, 2'x2'x4" CONCRETE PAD

EXISTING GRADE

24"

18" MIN.

INDIVIDUAL ANODE CABLES
TO ANODE JUNCTION BOX
OR RECTIFIER

NATIVE SOIL
BACKFILL

1" (MIN.) PVC VENT PIPE
PERFORATE LOWER 15'
IN COKE COLUMN

ANODE CABLE TYPE
& SIZE AS SPECIFIED

20'

12"

PETROLEUM COKE BREEZE
BACKFILL

ANODE SIZE & TYPE
AS SPECIFIED

12"

PVC PIPE CAP

12" OR AS
REQUIRED

DRAWN BY
ENGINEER T.S.H. 3/09

JOB NO.



FARWEST CORROSION CONTROL COMPANY
1480 W. Artesia Blvd. Gardena, California

TYPICAL CATHODIC PROTECTION
20' SEMI-DEEP DUAL ANODE
INSTALLATION

SIZE
A

DWG NO.
S-5L

FILE
S-5L

SCALE
NONE

REV
0

SHEET
1 of 1